



NOTES:

1. ALL EXPOSED PIPING AND FITTINGS TO BE GALVANIZED WITH THE EXCEPTION OF THE STORZ CONNECTION.
2. 40' MAX FROM FDC TO APPARATUS ACCESS LOCATION.
3. FOR NFPA 13R SYSTEMS (2-1/2" RISER AND SMALLER) SINGLE FDC.

EFFECTIVE: DECEMBER 30, 2016

	<p>TOWN OF FUQUAY-VARINA STANDARD DETAILS</p>	<p>FLUSH FIRE DEPARTMENT CONNECTION</p>	<p>DETAIL No. 140.04 SHEET 01 of 01</p>
---	---	---	---